

# FEDERAL ENERGY ACT REPORT

Reporting Period: October 1, 2015 to September 30, 2016

Source	Number	Percent
Tanks	37	62
Piping	9	15
Dispensers	11	18
Submersible Pumps	0	0
Delivery Problems	0	0
Other	3	5
	<b>60</b>	<b>100%</b>

	Tanks	
Cause	Number	Percent
Spill	1	2.7
Overfill	0	0
Physical/Mechanical Damage	0	0
Corrosion	21	56.8
Installation Problems	0	0
Other	0	0
Unknown	15	40.5
	<b>37</b>	<b>100%</b>

	Piping	
Cause	Number	Percent
Spill	1	11.1
Overfill	1	11.1
Physical/Mechanical Damage	1	11.1
Corrosion	0	0
Installation Problems	0	0
Other	1	11.1
Unknown	5	55.6
	<b>9</b>	<b>100%</b>

	Dispensers	
Cause	Number	Percent
Spill	4	36.4
Overfill	1	9.1
Physical/Mechanical Damage	0	0
Corrosion	1	9
Installation Problems	0	0
Other	0	0
Unknown	5	45.5
	<b>11</b>	<b>100%</b>

	Submersible Pumps	
Cause	Number	Percent
Spill	0	0
Overfill	0	0
Physical/Mechanical Damage	0	0
Corrosion	0	0
Installation Problems	0	0
Other	0	0
Unknown	0	0
	<b>0</b>	<b>0%</b>

	Delivery Problems	
Cause	Number	Percent
Spill	0	0
Overfill	0	0
Physical/Mechanical Damage	0	0
Corrosion	0	0
Installation Problems	0	0
Other	0	0
Unknown	0	0
	<b>0</b>	<b>0%</b>

	Other	
Cause	Number	Percent
Spill	1	33.3
Overfill	0	0
Physical/Mechanical Damage	0	0
Corrosion	0	0
Installation Problems	0	0
Other	1	33.3
Unknown	1	33.3
	<b>3</b>	<b>100%</b>